



**STATE OF LOUISIANA  
DEPARTMENT OF TRANSPORTATION AND DEVELOPMENT**

Materials and Testing  
5080 Florida Blvd.

Baton Rouge, Louisiana 70806-4123  
{Materials and Testing/Section22(225)248-4187}

BOBBY JINDAL  
GOVERNOR

SHERRI H. LEBAS, P.E.  
SECRETARY

October 7, 2010

Mr. Patrick Buckley  
Senior Staff Engineer  
Power Fasteners, Inc.  
2 Powers lane  
Brewster, NY 10509

**Re: Powers Fasteners AC100+Gold**

Dear Mr. Buckley

We have completed the evaluation of Powers Fasteners AC100+Gold which show conformity of this product with the Department's specifications Powers Fasteners AC100+Gold has therefore, been approved and added to the Qualified Products List 40 for Concrete Anchor Systems under the heading (C) Injection Systems and the Department's Qualified Products List 52 as an Adhesive Anchor System for Deformed Tie Bars and Dowel Bars.

**Qualified Products List 40**

**CONCRETE ANCHOR SYSTEMS**

**(C) INJECTION SYSTEMS**

Product Source Code Number	Product	Approx. Cure Time	Bolt Size mm (inches)	Minimum Embedment Depth mm (inches)	Working Loads		Source
					Pull-Out KN (lbs)	Shear KN (lbs)	
4072	AC100+ Gold	Refer to product data	9.5 (3/8)	85.7 (3-3/8)	8.9 (2005)	Data not available	Powers Fasteners, Inc. 2 Powers Lane Brewster, NY 10509
			12.7 (1/2)	114.3 (4-1/2)	19.4 (4355)		
			15.9 (5/8)	142.88 (5-5/8)	28.6 (6440)		
			19.1 (3/4)	171.4 (6-3/4)	37.4 (8400)		
			22.2 (7/8)	200.0 (7-7/8)	47.8 (10745)		
			25.4 (1)	228.6 (9)	53.3 (11975)		
			31.75 (1-1/4)	285.75 (11-1/4)	69.2 (15555)		

Mr. Patrick Buckley  
Senior Staff Engineer  
October 7, 2010  
Page 2

**Qualified Products List 52**

**ADHESIVE ANCHOR SYSTEMS FOR DEFORMED TIE BARS AND DOWEL BARS**

Product Source Code Number	Product	System	Source
5263	AC100 + Gold	Injection	<b>Powers Fasteners, Inc. 2 Powers Lane Brewster, NY 10509</b>

Should you have any questions about this approval, please contact McArthur Whitmore, Jr. at (225) 248-4115 or Khiet Ngo at (225) 248-4134

Sincerely,



Luanna Cambas., P.E.  
Materials Engineer Administrator

LC: mwjr.

cc: Francisco Gudiel  
Khiet Ngo  
Alton Booth  
Standards Unit