



Minnesota Department of Transportation

Office of Materials & Road Research

1400 Gervais Avenue
Maplewood, MN 55109-2044

Office Phone: 651-366-5592

Fax: 651-366-5461

April 5, 2013

(651) 366-5575

Mr. Robert Antoinette
Powers Fasteners Inc.
2 Powers Lane
Brewster, NY 10509

Re: Mn/DOT Approval of Pure 110+

Dear Mr. Antoinette:

The Minnesota Department of Transportation (Mn/DOT), Office of Materials and Road Research has reviewed the documentation you submitted for approval of Pure 110+ epoxy injection adhesive anchoring system. This product has been added to the "Mn/DOT Approved Concrete Anchorages" list. This approval is based on a minimum 3/8" diameter anchor with a minimum 3-3/8" embedment. This approval is also contingent upon satisfactory performance in the field.

Please note that it is the manufacturer's responsibility to immediately notify Mn/DOT if the product is changed or modified, or if the product is no longer being produced. If our testing determines that the product has changed, without prior notification from the manufacturer, the product may be removed from the approved product list.

All of our approved products are located on the Mn/DOT Concrete web site at <http://www.dot.state.mn.us/products/index.html>

If you have any questions or comments, please contact me at the above address.

Sincerely,

A handwritten signature in black ink, appearing to read 'R. S. Mulvaney', with a long horizontal stroke extending to the right.

Ronald S. Mulvaney, P.E.
Structural Concrete Engineer

Cc: File

An Equal Opportunity Employer

