

OHIO DEPARTMENT OF TRANSPORTATION



1980 West Broad Street
Columbus, Ohio 43223



Reply to:
Office of Materials Management
1600 West Broad Street, Columbus, Ohio 43223

May 3, 2010

Powers Fasteners, Inc.
Attn: Patrick Buckley
2 powers Lane
Brewster, NY 10509

Mr. Buckley,

This office has reviewed the test data you submitted for your product; AC 100+Gold a Vinyl ester adhesive for anchoring threaded rod and dowelling in concrete. The product meets the requirements of ODOT item 705.20 Non-shrink Non-metallic material, for use on application installation temperature of 23 degree F to 95degree. The product has been added to our qualified product lists (QPL).

The list is available for view@
<http://www.dot.state.oh.us/Divisions/ConstructionMgt/Materials/Pages/QPL.aspx>
Click on ODOT specification number705.20

If you have any questions feel free to call me at 614-275-1397.

Lloyd M. Welker, P.E.
Administrator

A handwritten signature in black ink, appearing to read "Amir Tehrani".

Amir Tehrani, Assistant Engineer
Cement & Concrete Section

Cc: LMW: BJS: AST