



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Transportation
MATERIALS AND QUALITY ASSURANCE
Two Capitol Hill, Room 018
Providence, RI 02903-1124

OFFICE (401) 222-2524
FAX (401) 222-3489
TDD (401) 222-4971

July 21, 2011

BRIAN H. SCHUTZ
POWERS FASTENERS, INC
2 POWERS LANE
BREWSTER, NY 10509

Subject: *Anchoring Adhesives*

Dear Mr. Schutz:

We have completed a review of Power Fasteners, Inc.'s PE1000+, T308+ and AC100+ Gold. At this time we are still investigating ongoing research results and are being very conservative with all adhesive approvals. The northeast region was surveyed on their acceptance of these adhesives and what testing is required for acceptance.

These anchoring adhesives conform to the requirements of AASHTO M235 and are acceptable on construction projects where product type, grade, and class conditions are met. They are not acceptable where sustained tensile-load overhead applications exist until all research results on adhesives in concrete are available. This acceptance will continue with satisfactory field performance. Please inform us of any material changes.

Sincerely,

Deborah Munroe

cc: M. Felag, mnf. file, pefile